

# **MARICOPA COUNTY HEALTH CODE**

## **CHAPTER IX**

### **TRAILER COACH PARKS**

#### **SECTION 4**

#### **WATER SUPPLY**

##### **REGULATION 1. General Provisions**

The water supply and distribution systems serving the trailer coach spaces and any service building shall comply with all applicable provisions of Chapter V, Water Supply, of the Health Code.

##### **REGULATION 2. Special Provisions**

- a. The water supply system shall be designed, constructed, and maintained to satisfy a supply demand of at least six (6) fixture units at a residual pressure of at least twenty (20) pounds per square inch at each trailer coach site, in addition to the water requirements of any service building.
- b. Each trailer coach space shall be provided with a water service pipe terminating at least four (4) inches above ground level. The pipe shall be located so as to provide reasonable protection against mechanical damage. A trailer coach directly connected to such water service pipe shall also be properly connected to an approved waste disposal system.
- c. Water at a minimum temperature of 120°F (49°C) shall be provided at all times in the service building for general sanitation use.
- d. When the source of water and the water supply system are developed on the trailer coach park site, they shall include water storage facilities of at least two hundred fifty (250) gallons per trailer coach space, in addition to the requirements of any service building.